

9180190, Thorsby

Box 297

Thorsby AB
T0C2P0
(780)789-3935

Leduc Environmental Public Health

4219 - 50 Street (780)980-4644
Leduc, AB T9E 8C9

Accession #: WE-17-0143841
AESRD Approval #: 0001217
EI/ProvLab Study #:

Environmental Microbiology

Collected Date 2017-12-27
Collected Time 08:30 MST

		Units
Total Coliforms by Enzyme Substrate *	ABSENT	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL

-----	-----
Drinking Water Sample Category	Treated Public
Water Sample Source	River
Received Date and Time	2017-12-27 1516
Analyzed Date	2017-12-27
ID Number	1241115
Sample Collected By	Dave B
Collected By Phone Number	780-920-8622
Sample Collection Site.	Res #2

2017-12-27 08:30 MST Total Coliforms by Enzyme Substrate:
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

LEGEND: @=Faxed *=Footnotes #=Corrected H=High

Cc:

**Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency**

9180190, Thorsby

Box 297

Thorsby AB
T0C2P0
(780)789-3935

Leduc Environmental Public Health

4219 - 50 Street (780)980-4644
Leduc, AB T9E 8C9

Accession #: WE-17-0143847
AESRD Approval #: 0001217
EI/ProvLab Study #:

Environmental Microbiology

Collected Date 2017-12-27
Collected Time 10:45 MST

		Units
Total Coliforms by Enzyme Substrate *	ABSENT	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL

-----	-----
Drinking Water Sample Category	Treated Public
Water Sample Source	River
Received Date and Time	2017-12-27 1517
Analyzed Date	2017-12-27
ID Number	1241116
Sample Collected By	Dave B
Collected By Phone Number	780-920-8622
Sample Collection Site.	Town Shop

2017-12-27 10:45 MST Total Coliforms by Enzyme Substrate:
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

LEGEND: @=Faxed *=Footnotes #=Corrected H=High

Cc:

**Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency**

9180190, Thorsby

Box 297

Thorsby AB
T0C2P0
(780)789-3935

Leduc Environmental Public Health

4219 - 50 Street (780)980-4644
Leduc, AB T9E 8C9

Accession #: WE-17-0143849
AESRD Approval #: 0001217
EI/ProvLab Study #:

Environmental Microbiology

Collected Date	2017-12-27
Collected Time	11:00 MST
Total Coliforms by Enzyme Substrate *	ABSENT
E coli by Enzyme Substrate	ABSENT

Drinking Water Sample Category	Treated Public
Water Sample Source	River
Received Date and Time	2017-12-27 1517
Analyzed Date	2017-12-27
ID Number	1241114
Sample Collected By	Dave B
Collected By Phone Number	780-920-8622
Sample Collection Site.	Clearwell

Units
per 100mL
per 100mL

2017-12-27 11:00 MST Total Coliforms by Enzyme Substrate:
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

LEGEND: @=Faxed *=Footnotes #=Corrected H=High

Cc:

**Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency**

9602584, Thorsby - Raw Source Water

PO Box 297

Thorsby AB
T0C2P0
(780)789-3935

Leduc Environmental Public Health

4219 - 50 Street (780)980-4644
Leduc, AB T9E 8C9

Accession #: WE-17-0143806
AESRD Approval #:
EI/ProvLab Study #:

Environmental Microbiology

Collected Date 2017-12-27
Collected Time 09:30 MST

		Units
Total Coliforms. *	<4	per 100mL
Thermotolerant Coliforms.	<4	per 100mL

-----	-----
Water Sample Category	Raw Water
Water Sample Source	River
Received Date and Time	2017-12-27 1515
Analyzed Date	2017-12-27
ID Number	1241117
Sample Collected By	Dave B
Collected By Phone Number	780-920-8622
Sample Collection Site	Raw tap

2017-12-27 09:30 MST Total Coliforms.:
Total and Thermotolerant Coliform testing performed by Membrane Filtration.

LEGEND: @=Faxed *=Footnotes #=Corrected H=High

Cc:

Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency