

**9180190, Thorsby**

Box 297

Thorsby AB  
T0C2P0  
(780)789-3935

**Leduc Environmental Public Health**

4219 - 50 Street (780)980-4644  
Leduc, AB T9E 8C9

**Accession #:** WE-18-0005268  
**AESRD Approval #:** 0001217  
**EI/ProvLab Study #:**

**Environmental Microbiology**

Collected Date	2018-01-15	
Collected Time	10:10 MST	
		<b>Units</b>
Total Coliforms by Enzyme Substrate *	ABSENT	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL
-----	-----	
Drinking Water Sample Category	Treated Public	
Water Sample Source	River	
Received Date and Time	2018-01-16 0700	
Analyzed Date	2018-01-16	
ID Number	1241138	
Sample Collected By	Dave B	
Collected By Phone Number	780-920-8622	
Sample Collection Site.	Clearwell	

2018-01-15 10:10 MST Total Coliforms by Enzyme Substrate:  
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

---

LEGEND:                      @=Faxed                      \*=Footnotes                      #=Corrected                      H=High

---

Cc:

**Information on this report relates only to this sample  
For further information contact the Environmental Public Health Agency**

**9180190, Thorsby**

Box 297

Thorsby AB  
T0C2P0  
(780)789-3935

**Leduc Environmental Public Health**

4219 - 50 Street (780)980-4644  
Leduc, AB T9E 8C9

**Accession #:** WE-18-0005269  
**AESRD Approval #:** 0001217  
**EI/ProvLab Study #:**

**Environmental Microbiology**

Collected Date	2018-01-15
Collected Time	10:30 MST
Total Coliforms by Enzyme Substrate *	ABSENT
E coli by Enzyme Substrate	ABSENT
-----	
Drinking Water Sample Category	Treated Public
Water Sample Source	River
Received Date and Time	2018-01-16 0700
Analyzed Date	2018-01-16
ID Number	1241137
Sample Collected By	Dave B
Collected By Phone Number	780-920-8622
Sample Collection Site.	M.R. House

**Units**  
per 100mL  
per 100mL

2018-01-15 10:30 MST Total Coliforms by Enzyme Substrate:  
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

---

LEGEND:                      @=Faxed                      \*=Footnotes                      #=Corrected                      H=High

---

Cc:

**Information on this report relates only to this sample**  
**For further information contact the Environmental Public Health Agency**

**9180190, Thorsby**

Box 297

Thorsby AB  
T0C2P0  
(780)789-3935

**Leduc Environmental Public Health**

4219 - 50 Street (780)980-4644  
Leduc, AB T9E 8C9

**Accession #:** WE-18-0005270  
**AESRD Approval #:** 0001217  
**EI/ProvLab Study #:**

**Environmental Microbiology**

Collected Date	2018-01-15	
Collected Time	09:00 MST	
		<b>Units</b>
Total Coliforms by Enzyme Substrate *	ABSENT	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL
-----		
Drinking Water Sample Category	Treated Public	
Water Sample Source	River	
Received Date and Time	2018-01-16 0700	
Analyzed Date	2018-01-16	
ID Number	1241140	
Sample Collected By	Dave B	
Collected By Phone Number	780-920-8622	
Sample Collection Site.	South Reservoir	

2018-01-15 09:00 MST Total Coliforms by Enzyme Substrate:  
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

---

LEGEND:                      @=Faxed                      \*=Footnotes                      #=Corrected                      H=High

---

Cc:

**Information on this report relates only to this sample  
For further information contact the Environmental Public Health Agency**

## 9602584, Thorsby - Raw Source Water

PO Box 297

Thorsby AB  
T0C2P0  
(780)789-3935

### Leduc Environmental Public Health

4219 - 50 Street (780)980-4644  
Leduc, AB T9E 8C9

**Accession #:** WE-18-0005223  
**AESRD Approval #:**  
**EI/ProvLab Study #:**

## Environmental Microbiology

Collected Date 2018-01-15  
Collected Time 11:00 MST

		<b>Units</b>
Total Coliforms. *	At least 8 *	per 100mL
Thermotolerant Coliforms.	<4	per 100mL

-----	-----
Water Sample Category	Raw Water
Water Sample Source	River
Received Date and Time	2018-01-16 0700
Analyzed Date	2018-01-16
ID Number	1241130
Sample Collected By	Dave
Collected By Phone Number	780-920-8622
Sample Collection Site	Raw tap

2018-01-15 11:00 MST Total Coliforms.:  
Total and Thermotolerant Coliform testing performed by Membrane Filtration.

2018-01-15 11:00 MST Total Coliforms.:  
Precise quantitation could not be done due to BACKGROUND GROWTH.

---

LEGEND:                      @=Faxed                      \*=Footnotes                      #=Corrected                      H=High

---

Cc:

**Information on this report relates only to this sample  
For further information contact the Environmental Public Health Agency**